

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. HHC/FBD/2025-26/21

Date: 16.5.25

It is certified that an inspection team headed by Vandana Deswal  
(Name of Officers with designation) from Dy Civil Surgeon Chemist Health Dept. FBD (Name of Department/Office) inspected the Modern Public School  
Sec 37 (Name & Address of the School) on \_\_\_\_\_ and found that the Modern Public School  
Sec 37 Faridabad (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 31.3.26.

Signature with Seal : Jayant  
Name : DR. Jayant Pajree  
Designation : \_\_\_\_\_  
DEPUTY CIVIL SURGEON  
FARIDABAD (HRY)

To  
Modern Public School  
Sec 37, Faridabad.  
\_\_\_\_\_  
(Name & Address of the Institution)

K. Anshu  
11-6-25  
Principal  
Modern Public School  
Sector - 37 Faridabad



Form No:- 718

Date:- 13/05/2025

**Physical / Chemical Examination Report of Water Sample**

Sample ID/Classification : FBD/00628/5/2025 / Private	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sender : Modern Public school	Collected By	Modern public ...
Location : , sector 37 faridabad	Collection Date	05/05/2025 at 13:21
Sample Description : Drinking Water	Received at lab	05/05/2025 at 15:19
Latitude / Longitude : 77.311142 / 28.482902	Analysis Start Date	06/05/2025
	Analysis End Date	08/05/2025
	Sample Quantity	1 litre

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.61	1 NTU	5 NTU	APHA 24th edition ,2130 B:2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
4	Color	6	5 Hazen Units	15 Hazen Units	APHA 24 th EDITION- 2120 C:2023
5	Total Dissolved Solids @ 180°C ± 2°C	110	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO3	50	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	10.42	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	5.83	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	38	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	41.24	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	17	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride as F	0.49	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
13	Iron as Fe	0.04	1.0 mg/lit.	1.0 mg/lit.	USEPA 45(126:43459):2023, APHA 24th EDITION 3500-Fe-B
14	Nitrate as No3	6.7	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	7.24	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

*[Handwritten Signature]*

VANDANA DESWAL ,CHEMIST  
DISTRICT WATER TESTING LABORATORY, FARIDABAD  
email:-chemist.fbad@phedharyana.gov.in

*[Handwritten Signature]*

*[Handwritten Signature]*  
11-6-25  
Principal  
Modern Public School  
Sector - 37 Faridabad

Memo No:- 722

Date: 13/5/2025

Subject: **Bacteriological Examination Report of Water Sample**

		Sample Details	Date & Time
Sample ID:	FBD/00626/5/2025	Collected By	modern public .9999891939
Sample Classification:	Private	Collection Date	05/05/2025 at 13:13
Sender:	Modern public school	Received at lab	05/05/2025 at 15:19
Location :-	, sector 37 faridabad	Tested at Lab	13/05/2025
Latitude :-	77.811254	Longitude :-	28.482888

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- \* The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.  
Based on the tested parameters, the water sample is found "**POTABLE**"



*Vandana*

VANDANA DESWAL, CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING  
LABORATORY, FARIDABAD  
email:-chemist.fbad@phedharyana.gov.in

-----End of Report-----.

*Kaushik*  
11-6-25

Principal  
Modern Public School  
Sector - 37 Faridabad